

# Display energy certificate (DEC)



Coast and Vale Learning Trust  
Main Building  
Newby & Scalby Primary School  
The Green  
SCARBOROUGH  
YO12 5JA

Operational rating

# D

Certificate number: 0075-8219-8157-6892-5144

Valid until: 29 March 2024

Total useful floor area: 2,792.8 square metres

## Energy performance operational rating

The building's energy performance operational rating is based on its carbon dioxide (CO<sub>2</sub>) emissions for the last year.

It is given a score and an operational rating on a scale from A (lowest emissions) to G (highest emissions).

The typical score for a public building is 100. This typical score gives an operational rating of D.

Score	Operational rating	This building	Typical
0-25	A		
26-50	B		
51-75	C		
76-100	D	80 D	
----- 100 -----			
101-125	E		
126-150	F		
150+	G		

## This building's energy use

Energy use	Electricity	Other fuels
Annual energy use (kWh/m <sup>2</sup> /year)	31.72	122.05
Typical energy use (kWh/m <sup>2</sup> /year)	40	153.14
Energy from renewables	0%	0%

## Previous operational ratings

Date	Operational rating
March 2023	80 D
March 2022	98 D
March 2021	88 D

## Total carbon dioxide (CO<sub>2</sub>) emissions

This tells you how much carbon dioxide the building emits. It shows tonnes per year of CO<sub>2</sub>.

Date	Electricity	Heating	Renewables
March 2023	49	66	0
March 2022	51	93	0
March 2021	45	86	0

## Assessment details

Assessor's name	Mr Stephen Armstrong
Employer/Trading name	North Yorkshire County Council
Employer/Trading address	County Hall, 1 Racecourse Lane, Northallerton, DL7 8AD
Assessor's declaration	Contractor to the occupier for EPBD services only.
Accreditation scheme	Elmhurst Energy Systems Ltd
Issue date	8 March 2023
Nominated date	30 March 2023

